

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. D H 0 / Shah. (S) / 2023 / D-589

Dated: - 13/9/23

It is certified that an inspection team headed by MOHD. KUTUBUDDIN(Name of Officers with designation) from MOHD. KUTUBUDDIN (PUBLIC HEALTH INSPECTOR)(Name of Department/ Office) inspected the BHARTI PUBLIC SCHOOL, KONDLI, MAYUR VIHAR PHASE III, DELHI-96 (Name & Address of the School) on01/09/23 (date of inspection) and found that the BHARTI PUBLICSCHOOL (Name of School) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.The above is valid for a period of 1 YEAR (FROM THE DATE OF ISSUANCE)Signature with Seal: Dr. Kanika SinghName: DR. KANIKA SINGHDesignation: DEPUTY HEALTH OFFICERName & Address of the Office / Department: M.C.D. / SHAHDARA SOUTH ZONE

To

BHARTI PUBLIC SCHOOL  
MAYUR VIHAR PHASE - 3

(Name &amp; Address of the Institution)

  
 PRINCIPAL  
 Bharti Public School  
 (Sr. Sec. Recognised)  
 Mayur Vihar, Delhi-96

BHARTI EDUCATIONAL TRUST

  
 SECRETARY

8

**MUNICIPAL CORPORATION OF DELHI**  
**Public Health Department**  
**Shahdara (South) Zone**  
**419, Udyog Sadan, Patparganj Industrial Area Delhi-110092**

No. DHO/Shah.(S)/2023/D-589

Dated:- 13/9/23


**School Health Certificate**

1. Name of School	: Bharti Public School
2. Location of the School	: New Kondli Mayur Vihar Ph-3 Delhi-110096
3. School Timing	: 08.00 AM to 02.00 PM
4. No. of Students	: 1547
5. No. of Doors in each room	: Provided
6. No. of Fans in each room	: Provided
7. Building Structure	: Pucca
8. No of Rooms	: 44
9. Electricity	: BSES
10. Water Supply	: DJB Bill
11. No of Toilets	: 40
12. No of Staff	: 65

At the time of inspection, school is found running under sanitary and hygiene conditions. This certificate has no bearing on unauthorized construction of the premises if any and on any dispute regarding title of land.

This certificate/NOC is valid for (01) one year only.

The Principal  
Bharti Public School  
New Kondli Mayur Vihar Ph-3 Delhi-110096

  
Deputy Health Officer  
Shahdara (South) Zone  
DEPUTY HEALTH OFFICER  
MUNICIPAL CORPORATION OF DELHI  
SHAHDARA (SOUTH) ZONE

**BHARTI EDUCATIONAL TRUST**

  
**SECRETARY**

  
**PRINCIPAL**  
Bharti Public School  
(Sr. Sec. Recognised)  
Mayur Vihar, Delhi-96





No.DJB/QCLTYR/PD/231101


DELHI JAL BOARD  
(GOVT. OF N.C.T. DELHI)  
QUALITY CONTROL LABORATORY,  
TRANS YAMUNA REGION TAHIRPUR DELHI-110093



Licence No- CRO/QM/L-8004274 as per IS/ISO 9001:2015

ACWA-TYR

Diary No. 766.....dt. 16/1/24



NO: DJB/ACWA(TYR)/2024.....

DATE: - 15-01-2024

Analysis report of DJB water supply samples collected from (1) Inlet (2) Outlet from M/S Bharti Public School, Mayur Vihar-III, Delhi-110096, for drinking purpose.

Ref. No- BPS/MV/2023-24/3184 dated:- 08-01-2024

Challan No: - 413, dated: - 09-01-2024

Date of collection : 11-01-2024

Date of collection : 11-01-2024						
S. No.	PARTICULARS	BIS:10500-2012 LIMITS		UNITS	RESULT	
		Desirable	Permissible		(1)	(2)
A.	Physical Examination					
1.	Colour	...	...	-	Clear	Clear
2.	Odour	...	...	-	Chlor.	Chlor.
3.	Turbidity	1.0	5.0	NTU	0.98	0.92
4.	pH Value	6.5-8.5	--	-	7.4	7.5
5.	Electrical Conductivity	--	--	µs/cm	208	210
6.	Total Dissolved Solids	500	2000	mg/l	135	136
B.	Chemical Examination					
7.	P <sup>th</sup> Alkalinity	...	...	mg/l	NIL	NIL
8.	Total Alkalinity	200	600	mg/l	72	74
9.	Total Hardness	200	600	mg/l	88	92
10.	Calcium as (Ca)	75	200	mg/l	24.8	23.2
11.	Magnesium as (Mg)	30	100	mg/l	6.24	8.16
12.	Ammonical Nitrogen	0.5	NO RELAXATION	mg/l	N.D	N.D
13.	Nitrite	...	....	mg/l	N.D	N.D
14.	Nitrate	45	NO RELAXATION	mg/l	2.60	2.84
15.	Sulphate	200	400	mg/l	30.52	29.31
16.	Chloride	250	1000	mg/l	10	12
17.	Fluoride	1.0	1.5	mg/l	0.28	0.22
18.	Total Iron	1.0	NO RELAXATION	mg/l	0.08	0.06
19.	Cyanide	0.05	NO RELAXATION	mg/l	N.D	N.D
20.	Residual Chlorine	0.2	1.0	mg/l	0.69	0.41
C.	Bacteriological Examination					
21.	Coliform count	Absent	NO RELAXATION	MPN/100ml	0	0

REMARKS:- On the basis of above tested parameters, both water samples conform BIS: 10500-2012 and can be considered fit for drinking purpose.

15/1/24  
CHEMIST

16/1/24  
CHEMIST

16-1-24  
BACT.

Asst. Chief Water Analyst  
DJB Govt. of N.C.T. of Delhi  
Quality Control Zonal Laboratory (Ty)  
Tahirpur Dilshad Garden, Delhi-93

BHARTI EDUCATIONAL TRUST

PRINCIPAL  
Bharti Public School  
(Sr. Sec. Recognised)  
SECRETARY Mayur Vihar, Delhi-96